ANNUAL ACCESSIBILITY AUDIT FOR UNITED METHODIST CHURCHES (¶2533.6), Scored Version



Church	I	District						
	Y	Ν	Description / Guidelines <i>(see page 4 for scoring instructions)</i>	Explain "N" answers (additional space on p. 5)				
1	IG IN	TO TH	IE CHURCH					
1- B			Clearly visible signs mark <u>or</u> direct people to accessible entrances					
2- B			1+ marked ADA parking spaces are on level ground near entrance					
3- G			Wheelchair users don't have to go behind parked cars, cross traffic					
4- S			At least 1 per 25 spaces is clearly marked with access symbol on					
			vertical signs and on pavement (# of accessible spaces:)					
5- B			Accessible parking spaces are 8' wide with adjacent 5' access aisle					
6- S			At least one accessible space is van accessible: 11' wide with clearly					
			marked adjacent 5' access aisle (or 8' space with 8' access aisle)					
7- B			36" wide curb cuts (curb ramps) are provided close to parking					
8- B			Route (sidewalk) from accessible parking to accessible building					
			entrance is smooth, flat, and at least 36" wide (width:)					
9- B			Entrance is level <u>or</u> has exterior ramp with non-slip surface and					
			minimum width of 36" between handrails (width:)					
10- S			Ramp has max. incline of 1:12 (length: rise: ratio:)					
			with no more than 30' between level landings, <u>or</u> entrance is level					
11- S			34-38" handrails are on both sides of exterior ramp/ stairs, lower					
			ramp railing is no higher than 4" above deck, <u>or</u> entrance is level					
12- B			There is a 60" x 60" level platform at entry door (size:) with					
12 C			space (~ 18") on pull side of door <u>or</u> automatic door opener used					
13- G			Automatic door opener available, <u>or</u> attended doorbell for assist					
14- B			Entrance door is 36" wide; threshold no more than beveled ½" high					
	NG AR	ROUN	D THE CHURCH					
15- B			Signs in entrances/ halls direct visitors and help them locate rooms					
16- B			Corridors are at least 36" wide and have non-glare floor surface					
			Objects that protrude more than 4" from the wall have a lower					
17- B			edge no higher than 27" above the floor, or a barrier such as a					
			planter or guard rail, to allow detection with a cane					
18- B			Multi-level buildings provide access to all common/ most program					
			areas via elevator, lift and/ or ramp(s), <u>or</u> building is on one level					
19- B			Interior doorways have a minimum of $32''$ clearance and thresholds are level or are no more than $\frac{1}{2}''$ high and beveled					
			Door handles to ADA bathrooms/ common areas are easy to grasp,					
20- S			operate with one hand (e.g. lever style) using less than 6 lbs. force					
			Carpet pile is even, no more than $\frac{1}{2}$ thick, with no or firm padding;					
21- S			floor mats have non-slip backing and are stable					
			Fire alarm controls and extinguishers are no more than 48"					
22- G			(h:) from floor; visual and auditory fire alarms are in place					
			At least one marked ADA unisex/ family restroom (<i>or one stall in</i>					
			male & female restrooms) is accessible from each floor; has ~60"x					
23- B			$60^{"}$ turning space with $33 - 36^{"}$ high wall-mounted grab bar next to					
			toilet extending 54" from back wall; toilet height $17 - 19$ " (h:)					
			27" sink clearance from floor (h:), w/ easy to operate controls					
24- S			(lever style, automatic, etc.), hot water & drain pipes are covered					
			Soap dispenser and paper towels are mounted no higher than 48"					
25- B			(h:) <u>or</u> placed on counter for access					
26- B			Bottom edge of at least one mirror is 40" or lower (h:)					

	Y	N	Description / Guidelines <i>(see page 4 for scoring instructions)</i>	Explain "N" answers					
			Drinking fountain is no higher than 36" with easy hand controls and	(additional space on p. 5)					
27- B			wheelchair clearance, <u>or</u> paper cups are provided						
28- B			Interior stairs/ ramps have handrails on both sides, <u>or</u> all one level						
29- S			Top/bottom step edges & ramp level changes marked, <u>or</u> one level						
	UAR	Y. CLA	ASSROOMS, AND FELLOWSHIP AREA						
30- B			At least 1-2 level pew cuts/spaces for wheelchair users are available						
			Wheelchair spaces are 33"x48" forward or 33"x60" side approach						
31- S			(size:), distributed throughout the room for choice in						
			seating, with view of pulpit/ screen when others stand						
32- G			Chancel area and choir loft are accessible, e.g. with ramp or lift						
33- S			Handrail(s) provided for steps to the chancel, <u>or</u> chancel is level						
34- B			At least one aisle in each space is 36" wide or more (w:)						
35- B			Fellowship - e.g. potlucks, coffee hour- is offered in accessible space						
			In fellowship area and classrooms at least one table has minimum						
36- B			of 27" clearance on the underside, and a maximum height of 34"						
37- B			1-2 sturdy chairs have armrests, seats ~18" from floor, & no wheels						
соми	IUNIC	CATIC	ONS AND ENVIRONMENT						
38- S			Members are sensitized about need to minimize use of fragrances						
			Soaps, cleaning products and other chemicals are fragrance free;						
39- G			candles are unscented and non-petroleum-based						
40- S			Projected words (e.g. song lyrics) use large font and good contrast						
41- B			Large print bulletin, song lyrics, & scriptures provided on request						
42- S			Braille or electronic documents provided upon advanced request						
43- B			Microphone used by all speakers or comments are repeated at mic.						
44- S			Assisted listening system (FM and/or loop) & receivers are available						
45- G			ASL sign language interpreter is provided upon advanced request						
46- S			Print/ e-mailed copies of sermon provided upon advanced request						
47- G			Captions are provided / turned on for videos and other media						
ATTITU	JDES	1		•					
			Accessibility measures and who to contact for questions described						
48- B			in bulletin, website, maps, Find-A-Church site, and/or signage						
40 D			Pastor(s), ushers, greeters, and leaders have learned and practice						
49- B			appropriate disability etiquette and hospitality						
			Signs, websites, <u>and/or</u> bulletin boards offer evidence that people						
50- S			with visible and hidden disabilities are welcome and included in the						
			life of the congregation, e.g. through support group info., photos						
51- B			Disruptions are accepted and incorporated into worship						
52- B			Qualified service animals (e.g. guide dogs) are welcome within the						
-			church building(s) including the sanctuary and fellowship hall						
53- B 54- S			Congregation works to use inclusive, person-first language in						
			worship, e.g. people are invited to "rise in body or in spirit"						
			Classes and programs are adapted <i>as needed</i> to facilitate active participation of children and adults with disabilities						
55- B			Disability Awareness Sunday ¶265.4 observed during past 1-2 years						
56- S			Gifts of persons with disabilities are identified and used in service,						
			worship, and leadership roles, and to help to improve access						
57- B			Needs of people on special diets are considered when food is						
F0 f			offered, including gluten-free & alcohol-free communion elements						
58- S			Transportation offered plus valet parking <u>or</u> parking lot assistance						
59- S			"Buddy" system offered for individuals needing 1:1 support						

GOALS FOR ACCESSIBILITY IMPROVEMENT FOR THE UPCOMING YEAR	Target Date
1.	
2.	
3.	
4.	
YES NO Request consultation from Conference Disability Concerns Committee	
Comments (continue on p. 5 or additional pages if needed):	
	Date
Signature of Pastor:	
	Date
Signature of Trustees Chairperson:	
Date Form Completed Charge Conference Date	
PLEASE PRINT NAMES AND PROVIDE PHONE NUMBER OR E-MAIL ADDRESS:	
Form completed by Contact information	
Contact person for church Contact information	
PLEASE NOTE:	
• This form is for use on existing buildings only; refer to current ADA & state regulations for co	nstruction or
major remodeling projects: <u>https://www.ada.gov/2010ADAstandards_index.htm</u> .	
 The survey should be completed by a team including a member of the trustees, and people w 	vith construction,
architecture and/or rehabilitation backgrounds. Include persons with disabilities and family r	
especially someone who uses a wheelchair and someone with low vision, in the process.	
• Interview individuals with disabilities and family members of children and adults with disabili	ties to learn how
welcoming your congregation is and to help set priorities.	
• This is not an all-inclusive listing of ADA guidelines or appropriate accommodations, but rathe	er represents
basic first steps that a church may take to begin to implement accessibility measures.	

- Resources are available through your conference Disability Concerns Committee (¶653) and through the
 DisAbility Ministry Committee of the UMC at https://umcdmc.org/resources/accessibility-and-unitedmethodist-churches/ (check subheadings, too) to help you plan and carry out improvements.
 - 3/5 Revised March 2019; Used with permission of the DisAbility Ministries Committee of the United Methodist Church

Scoring Instructions:

- Based on your findings, check Yes or No for each audit item. Focus on your main accessible entrance and on Sunday morning activities, especially worship. If the intent of the item is adequately met in a different way, e.g. greeters are posted throughout the morning on Sundays to open doors and provide directions (#13 and 15), mark it Yes. If you can and will fix the issue within a week or so, mark Yes. If an item occurs at least 85% of the time, e.g. microphone use in worship and large meetings, score it Yes. If only part of a multi-question item is met, mark that item as No unless alternatives are given, as designated by "<u>or</u>." If a system is in place to provide services, e.g. "buddy" companions or e-mailed order of worship for Braille users, mark Yes even if no one is using it. See Guidance for Completing the Accessibility Audit at <u>https://umcdmc.org</u> for further clarification.
- 2. Add the number of **Yes** responses in each badge category (<u>B</u>ronze, <u>S</u>ilver, and <u>G</u>old).
- 3. Compute the percentage of **Yes** responses in that badge category.
- In order to receive a badge at the designated level, the church needs to score at least 85% at that level and any lower levels, i.e. the church cannot receive <u>S</u>ilver if the <u>B</u>ronze level is not met.
 Examples:
- Church A scores 29/32 in the <u>B</u>ronze category (90%), 14/20 in the <u>S</u>ilver category (70%) and 2/7 in the <u>G</u>old category (28%). This church qualifies for the <u>B</u>ronze badge
- Church B scores 31/32 in the <u>B</u>ronze category (96%), 18/20 in the <u>S</u>ilver category (90%) and 4/7 in the <u>G</u>old category. This church may apply for a review to see if it qualifies for the <u>G</u>old badge.*

		Bronze (E	Basic)	Silver (Sat	isfactory)	Gold (Great)		
1. & 2. # of Yes responses		/32		/20		/7 +(bonus) =		
3.	percentage		%		%		%	
4.	85% or greater = badge	Yes	No	Yes	No	Yes*	No	

<u>**B**</u> = <u>**B**</u>ronze (<u>**B**</u>asic accessibility and accommodations)</u> – The church is welcoming and offers basic amenities needed for a person with a disability to participate, e.g. a place to park, a way to get into the building and sanctuary, a bathroom that is usable, etc. Most items at this level are low cost and can be easily provided, e.g. ushers and greeters trained in disability etiquette, website information on access. (*Verified by self-report, using this Annual Accessibility Audit for United Methodist Churches. Check* <u>https://umcdmc.org</u> for instructions on how to access your badge.)

<u>S</u> = <u>Silver (Satisfactory accessibility and accommodations)</u> – The church has many accessible features and offers accommodations for persons with a variety of disabilities including hearing loss and limited vision. Silver level items may cost a bit more and take more effort to put in place. While some areas are not yet fully accessible and inclusive, it is clear that the congregation is working towards accessibility. (*Verified by self-report, using this Annual Accessibility Audit for United Methodist Churches. Check <u>https://umcdmc.org</u> for instructions on how to access your badge.)*

<u>**G**</u> = <u>**Gold** (<u>**G**</u>reat accessibility and accommodations)</u> – The congregation has gone beyond ADA and strives to provide an accessible space and appropriate accommodations. The church welcomes individuals with varying disabilities and their families through intentional measures and ministries. Continued improvement is planned based on needs of members and the community. This church would be a good choice to host conference events per ¶716.2 of the *Book of Discipline*, and might mentor other churches. (*Verified by this Annual Accessibility Audit for United Methodist Churches <u>and an interview or site visit</u>. If your score reaches the <u>**G**</u>old level, contact your conference Disability Concerns Committee or check <u>https://umcdmc.org</u> for further instructions. The audit will be reviewed in more depth to reach the <u>**G**</u>old level. Additional measures you have taken may count as bonus <u>**G**</u>old points to reach 85% or more.)

Additional Space for Explanations of "No" Responses (include item #s) and/or Comments